



Certificate of Compliance

Certificate: 2474731 (LR 43674)

Master Contract: 157607

Project: 2474731

Date Issued: September 28, 2012

Issued to: Intertec Instrumentation Ltd

255 Henry Dr
Sarnia, ON N7T 7H5
Canada
Attention: Ted Zavitz

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Marin Banu

Issued by: Marin Banu, P. Eng.

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

CLASS 3211 87 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus -
Certified to US Standards

CSA Enclosure Type 4X and IP65

Non-metallic enclosures, Models DIABOX and MULTIBOX, rated as Enclosure Type 4X and IP65;
Watertight / Corrosion Resistant.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 0-10 - General Requirements Canadian Electrical Code, Part II

CAN/CSA Standard C22.2 No. 94.1-07 - Enclosures for Electrical Equipment, Non-Environmental
Considerations



Certificate: 2474731 (LR 43674)

Master Contract: 157607

Project: 2474731

Date Issued: September 28, 2012

- CAN/CSA Standard C22.2 No. 94.2-07 - Enclosures for Electrical Equipment, Environmental Considerations
- CAN/CSA-C22.2 No. 60529:05 - Degrees of protection provided by enclosures (IP Code)
- ANSI/UL Standard 50 - Enclosures for Electrical Equipment, Non-Environmental Considerations
- ANSI/UL Standard 50E - Enclosures for Electrical Equipment, Environmental Considerations
- ANSI/IEC 60529:2004 - Degrees of protection provided by enclosures (IP Code)